

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. – C/GZP/04

Dated: 15-07-2026

It is certified that an inspection team headed by **Sri Amarnath Yadav (A.E)**, District Level Water Analysis Laboratory, Ghazipur (Name of officers with designation) from UP Jal Nigam (Rural), Ghazipur (Name of Department/office) inspected the **S.S. Dev Public School Hetimpur, Zamania, Ghazipur** (Name & Address of the school) on **14.07.2026** (Date of inspection) and on the basis of water test report (Attached) Report no: **C/GZP/JULY/04** dated **15.07.2026** of **District Level Water Analysis Laboratory, Ghazipur (PHED)** lab certified that the **S.S. Dev Public School Hetimpur, Zamania, Ghazipur** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T. Govt.

- This certificate is valid till **01 Year from date of issue**. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Ghazipur

Signature with Seal: _____


Assistant Engineer
Division Office

Name: Sri Amarnath Yadav, U.P. Jal Nigam (Rural)
Designation: (A.E.) Ghazipur

Name & Address of the office/Department:
Khand Karyalay, U.P. Jal Nigam (Rural),

Ghazipur, Uttar Pradesh - 233001

To

Manager

S.S. Dev Public School
Hetimpur, Zamania, Ghazipur
(Name & Address of the institution)

Note- The certificate is to be issued by authorized officer/ PHED LAB / Local Bodies .

District Water Analysis Laboratory
2nd Floor, Alampatti Ghazipur (U.P.)
Drinking Water Sample Test Report

Report: 224/R (2026-27)

Date: 20-07-2026

Distt.: 45 Ghazipur Block: Zamania Gram Panchayat: Hetimpur Revenue Village: Hetimputr, Zamania, Ghazipur Habitation: Main Location: S.S. Dev Public School Hetimpur Zamania, Ghazipur (U.P.)

Name & Designation of Sample Collector: Principal, S.S. Dev Public School hetimpur Zamania Ghazipur (U.P.)

Date & Time of Sampling: 15-07-2026

Date of Analysis: 24-08-2026

(A) CHEMICAL ANALYSIS

	Unit	Test	Indian Standards	
	Mg/lit	Result	Acceptable / Cause of Rejection	
1. Total dissolved solids	„	142	500	2500
2. Chloride (as Cl)	„	64	200	1000
3. Total Hardness (as CaCO ₃)	„	148	200	600
4. Alkalinity	„	42	200	600
(a). Phenolphthalein				
(b) Methyl orange				
5. Sulphate	„	68	200	400
6. Nitrate (NO ₂) as Nitrite (NO ₂)	„	Nil		
7. Nitrate (NO ₃) AS Nitrate (NO ₃)	„	14	45	45
8. Fluorides as F	„	0.8	1.0	1.5
9. Residual Chlorine	„	-	0.2	0.5
10. Iron as Fe	„	0.1	0.1	0.3

(B) PHYSICAL EXAMINATION

a. Taste	Unobjectionable		Objectionable
b. Colour	5	12	25
c. Odour	unobjectionable		objectionable
d. Turbidity	1	5	10
e. pH	7.0 to 8.5	7.5	6.5 > to <9.2

Quality of Drinking water

Satisfactory / Unsatisfactory

INCHARGE LAB/ As.

